



March 2, 2020

Prospective Bidders

Page 1 of 1

Re: Addendum #1

#W2020-34-A
City of Wylie Twin Lakes Park Trail Project
Questions Deadline 2/28/20

=====

Questions:

Q1) In lieu of scarify and re-compact subgrade – haul in 4” of compacted flex-base?

The contractor will be allowed 6 inches of properly compacted flex-base in lieu of scarifying and re-compacting the subgrade.

Q2) Does the contractor need to spread the existing dirt on site to level the areas around the sidewalk?

The contractor is allowed to spread out the excess dirt from construction within the park area with prior City approval of the locations where the dirt will placed.

Vendors who may have already submitted a bid and feel this addendum may change their bid price may pick up their bid and return it **prior to March 6, 2020 @ 3:00 PM CST**. If picking up the bid is not feasible, any new bid submitted by your firm will supersede one previously submitted.

If you have any questions regarding this addendum, please contact the City of Wylie Purchasing Department, (972) 516-6131. Acknowledge receipt of this addendum by initialing in the appropriate space on the Vendor Acknowledgment Page if you have not previously submitted a bid.